



DECLARATION OF CONFORMITY SIL 2

Dixon Bayco Division of the Dixon Valve and Coupling Company declares under our sole responsibility that the products listed below conform to SIL 2 reliability rating per IEC 61508:2010.

Products: FT101 Series 5 wire sensors
FT151 Series 2 wire sensors
FT202 Series ROM sensors

This reliability rating has been independently verified by exida.

Assessment Certificate Number: DIX 2208016 C001

The Flotech Liquid Leven sensors listed above are considered SIL 2 capable and must be integrated into safety systems using the following parameters:

Product	λ_{SU}	λ_{DU}	#
FT101	791	101	26
FT151	805	53	15
FT202	357	33	21

Date of certification July 1, 2023

Garth Dexter
General Manager,
Dixon Bayco USA
June 24, 2024

Dixon Bayco

7280 Union Centre Blvd.
West Chester, OH 45014
www.dixonvalve.com

ph 513-874-8499
fax 513-874-8399